

# General Environmental Incident Summary

**Incident:** 4170      **Date/Time Notice:** 7/18/2016      **DEM Incident No:**

**Responsible Party:** Shermans LLC

**Date Incident:** 7/15/2016      **Time Incident:**      **Duration:**

**County:** Cass      **Twp:** 139      **Rng:** 49      **Sec:** 2      **Qtr:**

**Lat:** 46.88473      **Long:** -96.82505      **Method:** Interpolation from map

**Location Description:** 731 29th ST N Fargo, ND 58102

**Submitted By:** Hunter Hubrig

**Affiliation:** Fargo Cass Public Health

**Address:** 4630 15th Ave N

**City:** Fargo

**State:** ND

**Zip:**

**Received By:**

**Contact Person:**

1005 Main Ave E.  
West Fargo, ND 58078

**Distance Nearest Occupied Building:**

**Release Contained:** Yes

**Type of Incident:** Tank Leak

**Description of Released Contaminant:** Diesel Fuel

**Volume Spilled:** 25.00 gallons

**Ag Related:** No

**EPA Extremely Hazardous Substance:** Unknown

**Reported to NRC:** Unknown

**Cause of Incident:**

Valve on a 250 gallon diesel tank leaked while sitting on a construction trailer on the street.

**Risk Evaluation:**

None

**# of Fatalities:**

**# of Injuries:**

**Affected Medium:** 02 - water

**Potential Environmental Impacts:**

Most of the spill stayed on street. Small amount appeared to enter storm drain but could not see any noticeable contamination on standing water in drain.

**Action Taken or Planned:**

Fargo Fire Department responded to spill. Floor dry was applied to spill. Fire Department cleaned up floor dry and put in bags.

**Wastes Disposal Location:** Fargo Landfill

**Agencies Involved:** Local Fire Department, Local Emergency Manager

## ***Updates***

---

***Date:*** 7/18/2016    ***Status:*** Reviewed - No Action Required

***Author:*** Crowdus, Kory

***Updated Volume:***

***Notes:***

Spoke with personnel who had been at release site. Minimal amount may have entered storm drain, but it could not be visibly observed on the water. Remaining impact was soaked up with Floor Dry and disposed of. No further follow-up needed at this time.